



N	Affinità termale	L [m]	T	G [kg]	Sat. (R) [l/min]	Δp (R) [kPa]
1	LETTO_a	82,7	10	89,4	1,50	13,83
2	LETTO_b	82,7	10	94,8	1,35	14,46
3	BAGNO	61,5	10	104,6	1,65	14,46
4	SS_a	90,3	10	112,1	1,50	9,30
5	SS_b	100,1	10	114,9	1,55	9,30
6	SOGG.COTTURA_a	91,9	10	116,0	1,55	6,58
7	SOGG.COTTURA_a	105,2	10	129,1	2,10	6,58